ATTACHMENT J

TOWER SITE MAINTENANCE CHECK LIST

EQUIPMENT SHELTER (EXTERIOR)			
	Unused conduits and cable entry ports capped Openings to exterior sealed Exterior caulking Exterior grounding bar and grounding connections		
	Exterior light with sensor proper operation Equipment door lock system		
EQUI	PMENT SHELTER (INTERIOR)		
	Air-conditioning exhaust fan w/motorized damper working properly		
	Intake damper with filter working properly		
	Exhaust/Intake fan mesh clear of obstructions		
	Air-conditioning units proper operation		
_	Ventilation exhaust fan working properly		
	Baseboard heaters working properly		
	Alarm-Hi-temp working properly Alarm-Low-temp working properly		
	Alarm-Entry/Intrusion working properly		
	Alarm-Fire/Smoke working properly		
_	Filters replaced/cleaned		
_	Trash removed		
	Interior lights		
	Floor swept/cleaned		
FENCE AND GATE			
	Fencing integrity		
	Entry gate integrity Chain/Security lock		
	Cham/Security lock		

SITE GENERAL			
5112			
	Site mowed (if applicable)		
	Site clear of weeds		
	Fencing/Gate and 2 feet around the perimeter		
	of the fence clear of weeds		
	Site cleaned/clear of debris		
	Access road/cleaned clear of debris		
	Site overall appearance		